

Service Line Material Classification	Definition	Total Number of Service Lines (REQUIRED to be reported under the LCRR) <sup>x</sup>
Lead	Any portion of the service line is known to be made of lead. <sup>2</sup>	0
Galvanized Requiring Replacement (GRR)	The service line is not made of lead, but a portion is galvanized and the system is unable to demonstrate that the galvanized line was never downstream of a lead service line.	0
Non-Lead	All portions of the service line are known NOT to be lead or GRR through an evidence-based record, method, or technique.	332
Lead Status Unknown	The service line material is not known to be lead or GRR. For the entire service line or a portion of it (in cases of split ownership), there is not enough evidence to support material classification.	0
TOTAL		332